### **Tracer Lowbay 2 Installation**



#### 220-240V / 50-60Hz

IP20

Terminal Labelling:

L1 E ( ) N Emergency

Switched Live Earth Neutral

DA/AT3 DA/AT3 Dimming -/D1/DA +/D2/DA L3 Unswitched Live DALI Autotest DALI Autotest

DA Analogue/DSI/DALI
DA Analogue/DSI/DALI
Switch Dim /
Corridor Function









WARNING: Luminaire must be earthed. Risk of electric shock from LED boards if operated with cover removed. Installation / operation outside of luminaires intended scope invalidates warranty. Suitable only for domestic / light industrial / industrial applications within the scope of EN55015. Tested to compliance with BSEN 60598: specification for general requirements and tests. Must be installed by a suitably qualified person in accordance with all relevant legislation. Ambient operating temperature of 0°C to 25°C. If maximum operating temperature is exceeded luminaire will automatically dim / switch off. Terminal blocks are rated to 16A unless stated otherwise. The light source contained in this luminaire shall only be replaced by the manufacturer or his service agent or a similar qualified person. LUMINAIRES WITH EMERGENCY PACK: When supply is isolated battery output terminals may be live if battery is connected. Isolate mains and battery before servicing. Emergency luminaires require unswitched live connection taken from same phase as switched supply. When unswitched supply is connected status indicator illuminates green, when unswitched supply is disconnected indicator extinguishes and luminaire operates in emergency mode. 24 hour charge period required before undertaking full discharge test. Emergency test sheets provided should be used to record all emergency tests. Batteries should be replaced when 3 hour duration is not met. Excessive switching of permanent live may result in premature battery failure. Battery electrolyte can be harmful to eyes / open wounds, do not puncture, if electrolyte touches skin / eyes flush with water. Do not incinerate batteries.

	TRL180	TRL240	TRL300
Α	526	646	766
В	357	476	596
С	285	406	526
D	505	505	505
Е	250	250	250
Depth	90	90	90


For suspended installation, complete 'A' and then skip to step 7.

For trunking or solid ceiling fix, follow steps 1-8.








Suspend via 2x Y-fit wires (ordered separately). Do not suspend from single point!!



Remove 2x screw cover caps, then unscrew to release gear covers.








# **Tracer Lowbay 2 Installation**





## **Tracer Lowbay 2 Installation**



#### Maintenance 1) Disconnect luminaire Use a pan pozi before undertaking any screwdriver to remove maintenance or cleaning. components. 🧗 M<u>o</u>dule (2) Cleaning should be Please contact Battery undertaken on external parts Dextra for of the luminaire only using a assistance with slightly damp lint free cloth. spare component (3)To access fitting use a pan pozi screwdriver to remove x2 screws. LED circuit is located under the Driver LED Circuit diffuser and mask. Use a pan pozi screwdriver to remove.