

PTECF7 COB Installation

230-240V / 50-60Hz
IP20



WARNING - THIS LUMINAIRE MUST BE EARTHED

This luminaire has been tested and is manufactured to comply with BS EN 60598 : specification for general requirements and tests. It should be installed by a suitably qualified person in accordance with IEE.

CAUTION: there is a potential risk of electric shock from the LED boards when the product is operational with the cover removed.

NOTE: INSTALLATION AND OPERATION OF THE LUMINAIRE BEYOND ITS SCOPE OF SUPPLY WILL INVALIDATE THE WARRANTY.

DIL-0300-0061

<p>1.</p> <p>50mm minimum void space</p> <p>58mm height above ceiling</p> <p>68mm cut out</p> <p>85mm</p>	
<p>2.</p> <p>Isolate supply and then mark the desired position on ceiling for luminaire. Carefully cut 65mm diameter hole.</p>	<p>3.</p> <p>Remove fascia and switch cover.</p> <p>Move switch to select light colour: warm white, cool white, neutral white. Optionally change fascia finish.</p>
<p>4.</p> <p>Open driver housing and connect supply.</p> <p>Close housing, connect driver to lamp and insert in ceiling.</p>	<p>5.</p> <p>Fold spring clips up and carefully insert lamp into ceiling. Switch on supply and test.</p>